

CERTIFICATE

Issued to:
Applicant:
**Mete Enerji Kablo ve Elektrik Malzemeleri San ve.
Tic. A.S.**
**A.O.S.B. 10007 Sok No: 34
35620 Cigli Izmir, Turkey**

Licensee:
**Mete Enerji Kablo ve Elektrik Malzemeleri San ve.
Tic. A.S.**
**A.O.S.B. 10007 Sok No: 34
35620 Cigli Izmir, Turkey**

Product : 2-pole socket-outlet
Trade name(s) : ME
Type(s)/model(s) : 4040xxxxxx

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard NEN 1020:2019, NEN-IEC 60884-1:2019, NEN-IEC 60884-1:2019/A1:2019 and NEN-IEC 60884-1:2019/A2:2019
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 2155515


DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 16 October 2019 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 71-110510

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



R Zhou
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: 2-pole socket-outlet
Trade name(s)	: ME
Type(s)/model(s)	: 4040xxxxxx
Rated current	: 16 A
Rated voltage	: 250 V~
Standard sheet	: III of the CEE 7
Degree of protection	: IP44 or IP54
Method of mounting	: panel type, screw-fixing
Design	: rewirable, fixed
Terminals	: screw terminals
Earthing	: with side earthing contacts
Markings	: -tradename series-indication and electrical ratings on the base -tradename and suffix for the cover on this part

TESTS**Test requirements**

NEN 1020:2019
NEN-IEC 60884-1:2019
NEN-IEC 60884-1:2019/A1:2019
NEN-IEC 60884-1:2019/A2:2019

Test result

The test results are laid down in DEKRA test file 223572200.

Conclusion

The examination proved that all requirements were met.

Factory location

Mete Enerji Kablo ve Elektrik Malzemeleri San ve. Tic. A.S.
A.O.S.B. 10007 Sok No: 34
35620 Cigli Izmir, Turkey

CERTIFICATE

Issued to:
Applicant:
**METE ENERJI Kablo ve Elektrik
Malzemeleri San ve Ticaret A.Ş.**
A.O.S.B. 10007 Sok. No: 34
35620 Çiğli - İZMİR
Turkey

Manufacturer/Licensee:
**METE ENERJI Kablo ve Elektrik
Malzemeleri San ve Ticaret A.Ş.**
A.O.S.B. 10007 Sok. No: 34
35620 Çiğli - İZMİR
Turkey

Product(s) : plug, (2-pole)
Trade name(s) : ME
Type(s)/model(s) : 404001/2

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard IEC 60884-1:2002 + A1:2006 + A2:2013 and NEN 1020:1987 + A2:2004
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 2155515

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.


This certificate is issued on 23 October 2015 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 2183564.01

DEKRA Certification B.V.



drs. G.J. Zoetbrood
Managing Director



H.R.M. Barends
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

product	: plugs, (2-pole)
trade name(s)	: ME
type(s)	: 404001/2
rated current	: 16 A
rated voltage	: 250 V
earthing	: with side earthing contacts or with dual earthing contacts
design	: rewirable
standard sheet	: IV or VII
terminals	: screw-type terminals
description	: body of thermoplastic material
markings	: are shown on the body

List of components

Component	trade name	type/model	approval mark ¹⁾
cable clamp	METE ENERJI	20156	*
housing	METE ENERJI	20154	*

¹⁾ * indicates a component tested as part of the appliance

TESTS**Test requirements**

IEC 60884-1:2002 + A1:2006 + A2:2013
NEN 1020:1987 + A2:2004

Test result

The test results are laid down in DEKRA test file 2183564.01.

Remarks

This certificate replaces our certificate 2170909.01 dated 2014-12-04 and is also based on the results of that certificate.

Conclusion

The examination proved that all test requirements were met.

Tested by : T. Cai

Checked by : M.A.R. Bollen

**Factory locations**

METE ENERJI Kablo ve Elektrik
Malzemeleri San ve Ticaret A.Ş.
A.O.S.B. 10007 Sok. No: 34
35620 Çiğli - İZMİR
Turkey

CERTIFICATE

Issued to:
Applicant:
**METE ENERJI Kablo ve Elektrik
Malzemeleri San ve Ticaret A.Ş.**
A.O.S.B. 10007 Sok. No: 34
35620 Çiğli - İZMİR
Turkey

Manufacturer/Licensee:
**METE ENERJI Kablo ve Elektrik
Malzemeleri San ve Ticaret A.Ş.**
A.O.S.B. 10007 Sok. No: 34
35620 Çiğli - İZMİR
Turkey

Product : portable socket-outlet (2-pole)
Trade name : ME
Type/model : 404010/11

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard IEC 60884-1:2002 + A1:2006 + A2:2013 and NEN 1020:1987 + A2:2004
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 2155515

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.


This certificate is issued on 1 June 2015 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 2183564.02

DEKRA Certification B.V.



drs. G.J. Zoetbrood
Managing Director



H.R.M. Barends
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

product	:	portable socket-outlet (2-pole)
trade name	:	ME
type	:	404010/11
rated current	:	16 A
rated voltage	:	250 V
earthing	:	with side earthing contacts
degree of protection	:	IP44
design	:	rewirable, without shutters
standard sheet	:	III
terminals	:	screw-type terminals
description	:	body of thermoplastic material
markings	:	are shown on the body

List of components

Component	trade name	type/model	approval mark ¹⁾
cable clamp	METE ENERJI	20156	*
cover	METE EMERJI	20170	*
housing	METE ENERJI	20164	*

¹⁾ * indicates a component tested as part of the appliance

TESTS**Test requirements**

IEC 60884-1:2002 + A1:2006 + A2:2013
NEN 1020:1987 + A2:2004

Test result

The test results are laid down in DEKRA test file 2183564.02.

Remarks

This certificate replaces our certificate 2170916.01 dated 2014-11-27 and is also based on the results of that certificate.

Conclusion

The examination proved that all test requirements were met.

Tested by : T. Cai

Checked by : M.A.R. Bollen

**Factory locations**

METE ENERJI Kablo ve Elektrik
Malzemeleri San ve Ticaret A.Ş.
A.O.S.B. 10007 Sok. No: 34
35620 Çiğli - İZMİR
Turkey

CERTIFICATE

Issued to:
Applicant:
**METE ENERJI Kablo ve Elektrik
Malzemeleri San ve Ticaret A.Ş.
A.O.S.B. 10007 Sok. No: 34
35620 Çiğli - İZMİR
Turkey**

Manufacturer/Licensee:
**METE ENERJI Kablo ve Elektrik
Malzemeleri San ve Ticaret A.Ş.
A.O.S.B. 10007 Sok. No: 34
35620 Çiğli - İZMİR
Turkey**

Product : multiple portable socket-outlet (2-pole)
Trade name : ME
Type/model : 404014/15

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard IEC 60884-1:2002 + A1:2002 + A2:2013 and NEN 1020:1987 + A2:2004
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 2155515

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.


This certificate is issued on 1 June 2015 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 2183564.03

DEKRA Certification B.V.



drs. G.J. Zoetbrood
Managing Director



H.R.M. Barends
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

product	:	multiple portable socket-outlet (2-pole)
trade name	:	ME
type	:	404014/15
rated current	:	16 A
rated voltage	:	250 V
earthing	:	with side earthing contacts
degree of protection	:	IP44
design	:	rewirable, 3-fold, without shutters
standard sheet	:	III
terminals	:	screw-type terminals
description	:	body of thermoplastic material
markings	:	are shown on the body

List of components

Component	trade name	type/model	approval mark ¹⁾
terminal cover	METE ENERJI	20172	*
housing	METE ENERJI	20168	*
socket	METE ENERJI	20160	*
cover	METE ENERJI	20170	*

¹⁾ * indicates a component tested as part of the appliance

TESTS**Test requirements**

IEC 60884-1:2002 + A1:2006 + A2:2013
NEN 1020:1987 + A2:2004

Test result

The test results are laid down in DEKRA test file 2183564.03.

Remarks

This certificate replaces our certificate 2170911.01 dated 2015-02-06 and is also based on the results of that certificate.

Conclusion

The examination proved that all test requirements were met.

Tested by : T. Cai

Checked by : M.A.R. Bollen

**Factory locations**

METE ENERJI Kablo ve Elektrik
Malzemeleri San ve Ticaret A.Ş.
A.O.S.B. 10007 Sok. No: 34
35620 Çiğli - İZMİR
Turkey